

Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

Staff present: On File

<u>Public present</u>: David Schwierman; Bill Green; Dave Reynolds; John Minors; Daniel McBride

1) Basement footers-12" below finished grade application – Change in code to finished grade instead of undisturbed soil. May need forms for the footing.

2012 NC Residential Code R403.1.4 Minimum depth. (120611 Item B-15)

R403.1.4 Minimum depth. All exterior footings and foundation systems shall extend below the frost line specified in Table R301.2(1). In no case shall the bottom of the exterior footings be less than 12 inches below the undisturbed ground surface or engineered fill finished grade.

Exception: Frost protected footings constructed in accordance with Section R403.3 and footings and foundations erected on solid rock shall not be required to extend below the frost line.

The delayed effective date of this Rule is January 1, 2015.

The Statutory authority for Rule-making is G. S. 143-136; 143-138.

2) DOI website-formal interpretation postings – New section to interpretation.




3) ICF Foundation Walls-Inspections in lifts – Refer to manufacture specifications.



Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

- 4) Panel frame construction Engineering showed stick built house, needed to reevaluate construction. Panels were staples instead of nails that the engineer did not approve.
- 5) Poured foundation walls, subgrade letter for footers Policy is be on site or uploaded. We will still inspect but will be a turn down for the footing. Will need to call in footing inspection on next inspection. No neutral code to be entered.
- 6) Inspection cancellations Notes are required in the computer. Never cancel without notes.
- 7) Code changes/Code Books Now a 6 year cycle, updated on DOI web site. Looking to print amendments and give to the inspectors. The changes are done every quarter. Changed is the accessory structure and definition. Safety glazing change to the old way in the code before. Must be in the same plane. This for residential only.



R308.4 Hazardous locations. The following shall be considered specific hazardous locations for the purposes of glazing:

Glazing in all fixed and operable panels of swinging, sliding and bifold doors.

Exceptions:

- 1. Glazed openings of a size through which a 3-inch diameter (76 mm) sphere is unable to pass.
- 2. Decorative glazing.
- 2. Glazing in an individual fixed or operable panel adjacent to a in the same plane as the door where the nearest vertical edge is within 24-inches (610 mm) of the door in a closed position and whose bottom edge is less than 60 inches (1524 mm) above the floor or walking surface.

Exceptions:

- Decorative glazing.
- 2. When there is an intervening wall or other permanent barrier between the door and the glazing.
- Glazing in walls on the latch side of and perpendicular to the plane of the door in a closed position.
 Deleted.



Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

R101.2.1 Accessory buildings. Accessory buildings with any dimension greater than 12 feet (3658mm) must meet the provisions of this code. Accessory buildings may be constructed without a masonry or concrete foundation, except in coastal high hazard or ocean hazard areas, provided all of the following conditions are met:


- The accessory building shall not exceed 400 square feet (37m2) or one story in height;
- The building is supported on a wood foundation of minimum 2x6 or 3x4 mudsill of approved wood in accordance with Section R317; and
- 3. The building is anchored to resist overturning and sliding by installing a minimum of one ground anchor at each corner of the building. The total resisting force of the anchors shall be equal to 20 psf (958 Pa) times the plan area of the building.

R101.2.2 Accessory structures. Accessory structures are not required to meet the provisions of this code except decks, gazebos, retaining walls as required by Section R404.4, detached masonry chimneys built less than 10' from other buildings, pools or spas per appendix G, or detached carports.

Exception: Portable lightweight aluminum or canvas type carports not exceeding 400 sq ft or 12' mean roof height and tree houses supported solely by a tree are exempt from the provisions of this code.

The delayed effective date of this Rule is January 1, 2015. The Statutory authority for Rule-making is G. S. 143-136; 143-138.

8) Silica system approval – New decking material. Need letter on site that Lon MCSWAIN has approved.






Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

9) Engineer seals cannot pre-date the plans drawn date, require seal updates when plans change, cannot use another's seal – Look at the plans to verify dates. No seal date should before plan date.







Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

- 10) Plans received are having repeat items on required revisions Need correct problem on plans when resubmitted. A plan will go through plan review and revision are required. Next submittal all corrections are made, it goes to permitting. Within a couple days or a week or so later, similar plans (Same details, base plan etc.) and in some instances the same plans are submitted and no corrections are made from the previous reviews. Reviewers are back to square one redlining the plans that could have been corrected based on past reviews.
- 11) Still seeing old spans from the pre 1-1-2015 SP span charts. Please check with the designers to be sure using new span tables Need to look at the plan date that right spans being used. Big problem with decks.

2012 NC Residential Code Chapter 5, Chapter 8 Wood Tables SP. (130910 Item B-3)

Change the following tables in Chapter 5 as indicated in the attachment:

R502.3.1(1), R502.3.1(2), R502.3.3(1), R502.3.3(2), R502.5(1), R502.5(2)

Change the following tables in Chapter 8 as indicated in the attachment:

R802.4(1), R802.4(2), R802.5.1(1), R802.5.1(2), R802.5.1(3), R802.5.1(4), R802.5.1(5), R802.5.1(6), R802.5.1(7), R802.5.1(8)

http://www.ncdoi.com/OSFM/Engineering_and_Codes/Documents/2012_NCBuildingCode_amendments/130910%20B3%20RCh5,%20RCh8%20Wood%20Tables%20SP1.pdf

The delayed effective date of this Rule is January 1, 2015.

The Statutory authority for Rule-making is G. S. 143-136; 143-138.

12) Lumber in contact with ground requires ground contact lumber. Not all Pressure treated lumber is ground contact – Check label of the treated lumber. Ground contact when touching ground or within 16".





Residential

Date 6/03/2015 Recorder and minutes prepared by: Jay E. Garbus/Lon McSwain

13) Sq. ft. on plans is not matching sq. ft. on permit applications – Check square footage matches permit and plans to what is being built.

PROJECT		
JOB#	TYPE WORK ▼ PROPERTY USE ▼	
USDC#	EXPANDED FOOTPRINT SHELL BASEMENT SPRINKLER SYSTEM IS FULL DEMO	
PURPOSE	PROJECT DESCRIPTION (Residence,Office,etc) Mobile Home: include Yr,/Make/&Serial #	
OCC.TYPE	PROJECT AREA (sq. ft): NEW HEATED NEW UNHEATED DECK(S) # STORIES	
CONST	CONVERTED FROM UNHEATED TO HEATED SQ FT RENOVATE EXISTING SPACE: SQ FT	
MULTI-FAMILY: # HANDICAP UNITS	ONE/TWO FAMILY, MODULAR, MOBILE HOME: TOTAL # ROOMS # BEDROOMS # BATHS	
#TIANDICAF UNITS	WORK INCLUDES:	
TOTAL # UNITS	ATTACHED CARPORT ATTACHED GARAGE MASONRY FIREPLACE(S)	

- 14) Reconstruction vs. remodel 434 USDC for Reconstruction and a new CO (Affects permit fees.) when exceeding 50% (Existing Building code 2015) of the structure on removal of roof, walls, etc. Requiring a demolition permit will be a case by case basis Look at the plans and the existing building code. May need demolition permit also if no house is left.
- 15) Designers placing portal frame details on plans that will not meet the minimum requirements for the noted portal frame noted Check notes for wall bracing and plans requirements vs code requirements.
- 16) Pier/dock walkway requirements Regulation of sidewalk in not part of the residential code.

WE STRIVE TO PROVIDE EXCELLENT PLAN REVIEW AND INSPECTIONS WITH OUTSTANDING CUSTOMER SERVICE

Approved By Lon McSwain Date 06/10/2015	5
---	---